



KEARSLEY WASTEWATER TREATMENT WORKS - AUGUST MONTHLY POLLUTION MONITORING SUMMARY

Environment Protection Licence No. 3232
 Date Obtained: 2 September 2013
 Date Published: 16 September 2013

Licensee Hunter Water Corporation
 36 Honeysuckle Drive
 NEWCASTLE WEST NSW 2302

QUALITY MONITORING

EPA Id. No. 1 Site Code 5SL2600		Site Description - Discharge from No.2 Oxidation Pond											
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 August 2013 to 31 August 2013									Within Limits
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual		
pH	pH	Weekly	4	7.31	7.66	7.73	7.87	N/A	N/A	N/A	N/A	N/A	
Biochemical Oxygen Demand	milligrams per litre	Weekly	4	4	11	10	19	N/A	N/A	60	19	Yes	
Total Suspended Solids	milligrams per litre	Weekly	4	7	13	14	16	N/A	N/A	70	16	Yes	
Chlorophyll a	micrograms per litre	Weekly	3	16	26	19	42	N/A	N/A	N/A	N/A	N/A	
Nitrogen (ammonia)	milligrams per litre	Monthly	1	17.40	17.40	17.40	17.40	N/A	N/A	N/A	N/A	N/A	
Nitrogen (total)	milligrams per litre	Monthly	1	25.00	25.00	25.00	25.00	N/A	N/A	N/A	N/A	N/A	
Oil and Grease	milligrams per litre	Monthly	1	<5	<5	<5	<5	N/A	N/A	N/A	N/A	N/A	
Phosphorus (total)	milligrams per litre	Monthly	1	6.10	6.10	6.10	6.10	N/A	N/A	N/A	N/A	N/A	

*The licensee is not taken to have exceeded a quality limit specified in this licence for pH, BOD or TSS if the licensee shows that the level of chlorophyll-a in the oxidation ponds during any exceedance was 100 ug/L or more (showing that the exceedance was caused by excessive algal growth).