



KEARSLEY WASTEWATER TREATMENT WORKS - JULY MONTHLY POLLUTION MONITORING SUMMARY

Environment Protection Licence No. 3232
 Date Obtained: 5 August 2013
 Date Published: 19 August 2013

Licensee
 Hunter Water Corporation
 36 Honeysuckle Drive
 NEWCASTLE WEST NSW 2302

QUALITY MONITORING

EPA Id. No. 1 Site Code 5SL2600		Site Description - Discharge from No.2 Oxidation Pond											
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 July 2013 to 31 July 2013									Within Limits
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual		
pH	pH	Weekly	5	7.61	7.75	7.73	7.96	N/A	N/A	N/A	N/A	N/A	
Biochemical Oxygen Demand	milligrams per litre	Weekly	5	<2	3	4	5	N/A	N/A	60	5	Yes	
Total Suspended Solids	milligrams per litre	Weekly	5	1	5	4	10	N/A	N/A	70	10	Yes	
Chlorophyll a	micrograms per litre	Weekly	5	7	18	14	43	N/A	N/A	N/A	N/A	N/A	
Nitrogen (ammonia)	milligrams per litre	Monthly	1	14.00	14.00	14.00	14.00	N/A	N/A	N/A	N/A	N/A	
Nitrogen (total)	milligrams per litre	Monthly	1	20.01	20.01	20.01	20.01	N/A	N/A	N/A	N/A	N/A	
Oil and Grease	milligrams per litre	Monthly	1	<5	<5	<5	<5	N/A	N/A	N/A	N/A	N/A	
Phosphorus (total)	milligrams per litre	Monthly	1	5.80	5.80	5.80	5.80	N/A	N/A	N/A	N/A	N/A	

*The licensee is not taken to have exceeded a quality limit specified in this licence for pH, BOD or TSS if the licensee shows that the level of chlorophyll-a in the oxidation ponds during any exceedance was 100 ug/L or more (showing that the exceedance was caused by excessive algal growth).