



## KEARSLEY WASTEWATER TREATMENT WORKS - AUGUST MONTHLY POLLUTION MONITORING SUMMARY

Environment Protection Licence No. 3232  
 Date Obtained: 31 August 2015  
 Date Published: 16 September 2015

**Licensee** Hunter Water Corporation  
 36 Honeysuckle Drive  
 NEWCASTLE WEST NSW 2302

### QUALITY MONITORING

EPA Id. No. 1 Site Code 5SL2600		Site Description - Discharge from No.2 Oxidation Pond										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 August 2015 to 31 August 2015								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
pH	pH	Weekly	4	7.60	7.75	7.75	7.90	N/A	N/A	N/A	N/A	N/A
Biochemical Oxygen Demand	milligrams per litre	Weekly	4	6	7	7	8	N/A	N/A	60	8	Yes
Total Suspended Solids	milligrams per litre	Weekly	4	<1	9	11	15	N/A	N/A	70	15	Yes
Chlorophyll a	micrograms per litre	Weekly	4	4.30	13.45	11.65	26.20	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	Monthly	1	19.80	19.80	19.80	19.80	N/A	N/A	N/A	N/A	N/A
Nitrogen (total)	milligrams per litre	Monthly	1	21.35	21.35	21.35	21.35	N/A	N/A	N/A	N/A	N/A
Oil and Grease	milligrams per litre	Monthly	1	<5	<5	<5	<5	N/A	N/A	N/A	N/A	N/A
Phosphorus (total)	milligrams per litre	Monthly	1	6.20	6.20	6.20	6.20	N/A	N/A	N/A	N/A	N/A

\*The licensee is not taken to have exceeded a quality limit specified in this licence for pH, BOD or TSS if the licensee shows that the level of chlorophyll-a in the oxidation ponds during any exceedance was 100 ug/L or more (showing that the exceedance was caused by excessive algal growth).