



KEARSLEY WASTEWATER TREATMENT WORKS - JULY MONTHLY POLLUTION MONITORING SUMMARY

Environment Protection Licence No. 3232
 Date Obtained: 3 August 2015
 Date Published: 20 August 2015

Licensee Hunter Water Corporation
 36 Honeysuckle Drive
 NEWCASTLE WEST NSW 2302

QUALITY MONITORING

EPA Id. No. 1 Site Code 5SL2600		Site Description - Discharge from No.2 Oxidation Pond										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 July 2015 to 31 July 2015								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
pH	pH	Weekly	5	7.60	7.70	7.70	7.80	N/A	N/A	N/A	N/A	N/A
Biochemical Oxygen Demand	milligrams per litre	Weekly	5	3	7	6	16	N/A	N/A	60	16	Yes
Total Suspended Solids	milligrams per litre	Weekly	5	<1	7	8	17	N/A	N/A	70	17	Yes
Chlorophyll a	micrograms per litre	Weekly	5	6	9	9	11	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	Monthly	1	16.60	16.60	16.60	16.60	N/A	N/A	N/A	N/A	N/A
Nitrogen (total)	milligrams per litre	Monthly	1	20.51	20.51	20.51	20.51	N/A	N/A	N/A	N/A	N/A
Oil and Grease	milligrams per litre	Monthly	1	<5	<5	<5	<5	N/A	N/A	N/A	N/A	N/A
Phosphorus (total)	milligrams per litre	Monthly	1	6.00	6.00	6.00	6.00	N/A	N/A	N/A	N/A	N/A

*The licensee is not taken to have exceeded a quality limit specified in this licence for pH, BOD or TSS if the licensee shows that the level of chlorophyll-a in the oxidation ponds during any exceedance was 100 ug/L or more (showing that the exceedance was caused by excessive algal growth).