



KEARSLEY WASTEWATER TREATMENT WORKS - AUGUST MONTHLY POLLUTION MONITORING SUMMARY

Environment Protection Licence No. 3232
 Date Obtained: 5 September 2016
 Date Published: 16 September 2016

Licensee Hunter Water Corporation
 36 Honeysuckle Drive
 NEWCASTLE WEST NSW 2302

QUALITY MONITORING

EPA Id. No. 1 Site Code 5SL2600		Site Description - Discharge from No.2 Oxidation Pond											
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 August 2016 to 31 August 2016									Within Limits
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual		
pH	pH	Weekly	5	7.3	7.7	7.7	7.9	N/A	N/A	N/A	N/A	N/A	
Biochemical Oxygen Demand	milligrams per litre	Weekly	5	<2	9	9	17	N/A	N/A	60	17	Yes *	
Total Suspended Solids	milligrams per litre	Weekly	5	7	16	14	31	N/A	N/A	70	31	Yes *	
Chlorophyll a	micrograms per litre	Weekly	5	4	40	20	92.7	N/A	N/A	N/A	N/A	N/A	
Nitrogen (ammonia)	milligrams per litre	Monthly	1	19.4	19.4	19.4	19.4	N/A	N/A	N/A	N/A	N/A	
Nitrogen (total)	milligrams per litre	Monthly	1	23.9	23.9	23.9	23.9	N/A	N/A	N/A	N/A	N/A	
Oil and Grease	milligrams per litre	Monthly	1	<2	<2	<2	<2	N/A	N/A	N/A	N/A	N/A	
Phosphorus (total)	milligrams per litre	Monthly	1	7.6	7.6	7.6	7.6	N/A	N/A	N/A	N/A	N/A	

*The licensee is not taken to have exceeded a quality limit specified in this licence for pH, BOD or TSS if the licensee shows that the level of chlorophyll-a in the oxidation ponds during any exceedance was 100 ug/L or more (showing that the exceedance was caused by excessive algal growth).