



RAYMOND TERRACE WASTEWATER TREATMENT WORKS - SEPTEMBER MONTHLY POLLUTION MONITORING SUMMARY

Environment Protection Licence No. 217
 Date Obtained: 2 October 2012
 Date Published: 15 October 2012

Licensee Hunter Water Corporation
 36 Honeysuckle Drive
 NEWCASTLE WEST NSW 2302

QUALITY MONITORING

EPA Id. No. 2 Site Code 5DE1500		Site Description - At the discharge point at UV Disinfection									
Pollutant	Unit of Measurement	Sampling Frequency	Monthly Summary 1 September 2012 to 30 September 2012								
			Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	Weekly	<2	<2	<2	<2	N/A	N/A	30	<2	Yes
Faecal Coliforms	colony forming units per 100 mL	Weekly	0	3	1	11	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	Weekly	0.71	1.15	1.15	1.60	N/A	N/A	N/A	N/A	N/A
Nitrate + Nitrite (oxidised nitrogen)	milligrams per litre	Weekly	0.59	0.87	0.80	1.30	N/A	N/A	N/A	N/A	N/A
Oil and Grease	milligrams per litre	Fortnightly	<5	<5	<5	<5	N/A	N/A	N/A	N/A	N/A
Phosphorus (total)	milligrams per litre	Weekly	0.15	0.20	0.21	0.24	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Weekly	3	5	5	8	N/A	N/A	30	8	Yes
pH	pH	Weekly	7.00	7.15	7.15	7.29	N/A	N/A	6.50 - 8.50	7.00- 7.29	Yes

EPA Id. No. 1 Site Code 5OV1500		Site Description - At the discharge from the No.2 Maturation Pond									
Pollutant	Unit of Measurement	Sampling Frequency	Monthly Summary 1 September 2012 to 30 September 2012								
			Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	Daily during and Discharge	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Faecal Coliforms	colony forming units per 100 mL	Daily during and Discharge	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	Daily during and Discharge	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrate + Nitrite (oxidised nitrogen)	milligrams per litre	Daily during and Discharge	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Oil and Grease	milligrams per litre	Daily during and Discharge	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Phosphorus (total)	milligrams per litre	Daily during and Discharge	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Daily during and Discharge	-	-	-	-	N/A	N/A	N/A	N/A	N/A
pH	pH	Daily during and Discharge	-	-	-	-	N/A	N/A	N/A	N/A	N/A