



RAYMOND TERRACE WASTEWATER TREATMENT WORKS - SEPTEMBER MONTHLY POLLUTION MONITORING SUMMARY

Environment Protection Licence No. 217
 Date Obtained: 30 September 2013
 Date Published: 14 October 2013

Licensee Hunter Water Corporation
 36 Honeysuckle Drive
 NEWCASTLE WEST NSW 2302

QUALITY MONITORING

EPA Id. No. 2 Site Code 5DE1500		Site Description - At the discharge point at UV Disinfection										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 September 2013 to 30 September 2013								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	Weekly	4	<2	3	2	4	N/A	N/A	30	4	Yes
Faecal Coliforms	colony forming units per 100 mL	Weekly	4	0	0	0	0	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	Weekly	4	0.11	0.14	0.13	0.21	N/A	N/A	N/A	N/A	N/A
Nitrate + Nitrite (oxidised nitrogen)	milligrams per litre	Weekly	4	2.80	3.15	3.15	3.50	N/A	N/A	N/A	N/A	N/A
Oil and Grease	milligrams per litre	Fortnightly	2	<5	<5	<5	<5	N/A	N/A	N/A	N/A	N/A
Phosphorus (total)	milligrams per litre	Weekly	4	0.07	0.10	0.09	0.15	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Weekly	4	<1	2	2	5	N/A	N/A	30	5	Yes
pH	pH	Weekly	4	7.21	7.27	7.26	7.36	N/A	N/A	6.50 - 8.50	7.21 - 7.36	Yes

EPA Id. No. 1 Site Code 5OV1500		Site Description - At the discharge from the No.2 Maturation Pond										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting #	Monthly Summary 1 September 2013 to 30 September 2013								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	Daily during and Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Faecal Coliforms	colony forming units per 100 mL	Daily during and Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	Daily during and Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrate + Nitrite (oxidised nitrogen)	milligrams per litre	Daily during and Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Oil and Grease	milligrams per litre	Daily during and Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Phosphorus (total)	milligrams per litre	Daily during and Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Daily during and Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
pH	pH	Daily during and Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A

No samples were collected as no overflow occurred during the month