



RAYMOND TERRACE WASTEWATER TREATMENT WORKS - FEBRUARY MONTHLY POLLUTION MONITORING SUMMARY

Environment Protection Licence No. 217
 Date Obtained: 4 March 2013
 Date Published: 15 March 2013

Licensee Hunter Water Corporation
 36 Honeysuckle Drive
 NEWCASTLE WEST NSW 2302

QUALITY MONITORING

EPA Id. No. 2 Site Code 5DE1500		Site Description - At the discharge point at UV Disinfection										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 February 2013 to 28 February 2013								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	Weekly	4	<2	2	<2	2	N/A	N/A	30	2	Yes
Faecal Coliforms	colony forming units per 100 mL	Weekly	4	0	1	1	1	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	Weekly	4	<0.02	0.18	0.14	0.40	N/A	N/A	N/A	N/A	N/A
Nitrate + Nitrite (oxidised nitrogen)	milligrams per litre	Weekly	4	3.00	3.93	3.85	5.00	N/A	N/A	N/A	N/A	N/A
Oil and Grease	milligrams per litre	Fortnightly	2	<5	<5	<5	<5	N/A	N/A	N/A	N/A	N/A
Phosphorus (total)	milligrams per litre	Weekly	4	0.10	0.14	0.15	0.16	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Weekly	4	<1	1	<1	1	N/A	N/A	30	1	Yes
pH	pH	Weekly	4	6.90	7.26	7.32	7.52	N/A	N/A	6.50 - 8.50	6.90 - 7.52	Yes

EPA Id. No. 1 Site Code 5OV1500		Site Description - At the discharge from the No.2 Maturation Pond										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 February 2013 to 28 February 2013								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	Daily during and Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Faecal Coliforms	colony forming units per 100 mL	Daily during and Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	Daily during and Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrate + Nitrite (oxidised nitrogen)	milligrams per litre	Daily during and Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Oil and Grease	milligrams per litre	Daily during and Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Phosphorus (total)	milligrams per litre	Daily during and Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Daily during and Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
pH	pH	Daily during and Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A