



RAYMOND TERRACE WASTEWATER TREATMENT WORKS - FEBRUARY MONTHLY POLLUTION MONITORING SUMMARY

Environment Protection Licence No. 217
 Date Obtained: 2 March 2016
 Date Published: 22 March 2016

Licensee Hunter Water Corporation
 36 Honeysuckle Drive
 NEWCASTLE WEST NSW 2302

QUALITY MONITORING

EPA Id. No. 2 Site Code 5DE1500		Site Description - At the discharge point at UV Disinfection										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting	Monthly Summary 1 February 2016 to 29 February 2016								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	Weekly	4	<2	2	<2	2	N/A	N/A	30	2	Yes
Faecal Coliforms	colony forming units per 100 mL	Weekly	4	0	1	1	3	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	Weekly	4	<0.05	<0.05	<0.05	<0.05	N/A	N/A	N/A	N/A	N/A
Nitrate + Nitrite (oxidised nitrogen)	milligrams per litre	Weekly	4	5.30	5.73	5.75	6.10	N/A	N/A	N/A	N/A	N/A
Oil and Grease	milligrams per litre	Fortnightly	2	<2	<2	<2	<2	N/A	N/A	N/A	N/A	N/A
Phosphorus (total)	milligrams per litre	Weekly	4	0.13	0.25	0.25	0.36	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Weekly	4	1	3	3	6	N/A	N/A	30	6	Yes
pH	pH	Weekly	4	7.3	7.4	7.5	7.5	N/A	N/A	6.5 - 8.5	7.3 - 7.5	Yes

EPA Id. No. 1 Site Code 5OV1500		Site Description - At the discharge from the No.2 Maturation Pond										
Pollutant	Unit of Measurement	Sampling Frequency	No. of times measured during the month for licence reporting #	Monthly Summary 1 February 2016 to 29 February 2016								
				Minimum	Mean Value	Median Value	Maximum	3DGM Limit	3DGM Actual	100%ile Limit	100%ile Actual	Within Limits
Biochemical Oxygen Demand	milligrams per litre	Daily during and Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrogen (ammonia)	milligrams per litre	Daily during and Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Nitrate + Nitrite (oxidised nitrogen)	milligrams per litre	Daily during and Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Oil and Grease	milligrams per litre	Daily during and Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Phosphorus (total)	milligrams per litre	Daily during and Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
Total Suspended Solids	milligrams per litre	Daily during and Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A
pH	pH	Daily during and Discharge	-	-	-	-	-	N/A	N/A	N/A	N/A	N/A